

<b>Recordall® Compound Series</b>	<b>Correction Factors</b>	<b>Application Brief</b>
---------------------------------------	---------------------------	------------------------------

Compound Series registers mounted on incorrect meter size and/or location (Low or High). To obtain correct usage or registration, multiply reading on register by the correction factor indicated in appropriate box.

**RECORDALL® COMPOUND SERIES:**

**METER SIZE AND REGISTER POSITION ON METER**

**RECORDALL COMPOUND SERIES LOCAL REGISTER  
PLUS LOW OR HIGH POSITION DESIGNATION**

	<b>2"/3" Low</b>	<b>2" High</b>	<b>3" High</b>	<b>4"/6" Low</b>	<b>4" High</b>	<b>6" High</b>
<b>2"/3" Low</b>	1.00	129.0627	124.1041	1.5660	119.0972	1321.807
<b>2" High</b>	.007748	1.00	.961538	.012132	.922935	10.2409
<b>3" High</b>	.008058	1.0400	1.00	.012570	.959877	10.6508
<b>4"/6" Low</b>	.63857	82.4265	79.5558	1.00	76.0621	844.1798
<b>4" High</b>	.008397	1.0835	1.0418	.013147	1.00	11.0958
<b>6" High</b>	.0007565	.097648	.093890	.001185	.090124	1.00

These correction factors apply for consistent units of measure (gallons desired and gallons on the incorrect register).

**RCS-E-01**

Recordall® is a registered trademark of Badger Meter, Inc.

6-02



Please see our website at  
**[www.badgermeter.com](http://www.badgermeter.com)**  
for specific contacts.

Due to continuous research, product improvements and enhancements, Badger Meter reserves the right to change product or system specifications without notice, except to the extent an outstanding bid obligation exists.



**BadgerMeter, Inc.**

P.O. Box 245036, Milwaukee, WI 53224-9536  
(800) 876-3837 / Fax: (888) 371-5982  
[www.badgermeter.com](http://www.badgermeter.com)